SIEMENS

Data sheet

3SU1802-0AC10-4HB1




AS-Interface enclosure for command devices, 22 mm, round, Enclosure material plastic, enclosure top part gray, 2 control points plastic, Recess for labels, B=Pushbutton white, label: I, 1 NO, spring-type terminal, A=Pushbutton black label: O 1 NC, spring-type terminal, floor mounting, Insulation displacement system on top, Labels enclosed


www.du.et.hvev.ed.weve.e			
product brand name	SIRIUS ACT		
product designation	Enclosures		
product type designation	3SU1		
equipment of commanding and signaling device	A = Pushbutton / B = Pushbutton		
manufacturer's article number			
 of supplied contact module 	A1 = 3SU1400-2AA10-3CA0 / B2 = 3SU1400-2AA10-3BA0		
 of supplied contact module at the command point A 1 	<u>3SU1400-2AA10-3CA0</u>		
 of supplied contact module at the command point B 2 	<u>3SU1400-2AA10-3BA0</u>		
 of supplied communication module 	AB = 3SU1400-2EK10-6AA0		
 of the supplied holder 	A = 3SU1500-0AA10-0AA0, B = 3SU1500-0AA10-0AA0		
 of the supplied holder at the command point A 	<u>3SU1500-0AA10-0AA0</u>		
 of the supplied holder at the command point B 	<u>3SU1500-0AA10-0AA0</u>		
 of the supplied actuator 	A = 3SU1000-0AB10-0AA0 / B = 3SU1000-0AB60-0AA0		
 of the supplied actuator at the command point A 	<u>3SU1000-0AB10-0AA0</u>		
 of the supplied actuator at the command point B 	<u>3SU1000-0AB60-0AA0</u>		
 of supplied empty enclosure 	<u>3SU1802-0AA00-0AB1</u>		
 of supplied accessory 	A = 3SU1900-0AF16-0QA0, B = 3SU1900-0AF16-0QB0		
 of the supplied accessories at the command point A 	<u>3SU1900-0AF16-0QA0</u>		
 of the supplied accessories at the command point B 	<u>3SU1900-0AF16-0QB0</u>		
Enclosure			
design of the housing	with recess for label		
shape of the enclosure front	rectangular		
material of the enclosure	plastic		
number of command points	2		
product component			
EMERGENCY STOP device	No		
protective collar	No		
color of the enclosure top part	grey		
delivery state			
● as a kit	No		
pre-wired on strip terminal	Yes		
	Yes Vertical		
• pre-wired on strip terminal			
pre-wired on strip terminal fastening method of the enclosure			
pre-wired on strip terminal fastening method of the enclosure Actuator	Vertical		
pre-wired on strip terminal fastening method of the enclosure Actuator design of the actuating element	Vertical Pushbutton / pushbutton		
pre-wired on strip terminal fastening method of the enclosure Actuator design of the actuating element suitability for use EMERGENCY OFF switch	Vertical Pushbutton / pushbutton No		
pre-wired on strip terminal fastening method of the enclosure Actuator design of the actuating element suitability for use EMERGENCY OFF switch product feature lockout	Vertical Pushbutton / pushbutton No No		
pre-wired on strip terminal fastening method of the enclosure Actuator design of the actuating element suitability for use EMERGENCY OFF switch product feature lockout product extension optional light source	Vertical Pushbutton / pushbutton No No No		


	0			
number of contact modules	2			
type of unlocking device Front ring	A = none / B = none			
	Vee			
product component front ring	Yes Standard			
design of the front ring material of the front ring				
color of the front ring	plastic black			
Holder	DIACK			
material of the holder	Plastic			
Display				
number of LED modules	0			
General technical data				
product function				
positive opening	Yes			
EMERGENCY OFF function	No			
EMERGENCY STOP function	No			
protection class IP	IP66, IP67, IP69(IP69K)			
degree of protection NEMA rating	1, 2, 3, 3R, 4, 4X, 12K, 13			
shock resistance				
according to IEC 60068-2-27	sinusoidal half-wave 15g / 11 ms			
 for railway applications according to EN 61373 	Category 1, Class B			
vibration resistance				
 according to IEC 60068-2-6 	10 500 Hz: 5g			
 for railway applications according to EN 61373 	Category 1, Class B			
reference code according to IEC 81346-2	S			
continuous current of the C characteristic MCB	10 A; for a short-circuit current smaller than 400 A			
continuous current of the quick DIAZED fuse link	10 A			
continuous current of the DIAZED fuse link gG	10 A			
Substance Prohibitance (Date)	10/01/2014			
operating voltage				
• at AC				
— at 50 Hz rated value	18 31.6 V			
— at 60 Hz rated value	18 31.6 V			
at DC rated value	18 31.6 V Adapter ASI changed cable (insulation displacement method) M20 cable entry			
cable entry type	Adapter ASI shaped cable (insulation displacement method) M20 cable entry			
Communication/ Protocol design of the interface for communication	AS-i			
type of electrical connection of the communication interface	Insulation piercing technology top/right			
Auxiliary circuit	insulation picroing technology topright			
design of the contact of auxiliary contacts	Silver alloy			
number of NC contacts for auxiliary contacts	1			
number of NO contacts for auxiliary contacts	1			
Connections/ Terminals				
type of electrical connection of modules and accessories	Spring-type terminal			
type of electrical connection on enclosure	Adapter ASI shaped cable (insulation displacement method)			
tightening torque of the screws in the bracket	1 1.2 N·m			
tightening torque of fixing screws in the enclosure cover	1.5 1.7 N·m			
Ambient conditions				
ambient temperature				
during operation	-25 +70 °C			
during storage	-40 +80 °C			
environmental category during operation according to IEC 60721	3M6, 3S2, 3B2, 3C3, 3K6 (with relative air humidity of 10 95%, no condensation in operation permitted for all devices behind front panel)			
Installation/ mounting/ dimensions				
fastening method of modules and accessories	Floor mounting			
height	134.4 mm			
width	85 mm			
depth	75 mm			
shape of the installation opening	round			
Accessories				


		0			
		2			
•	g of the name plate for command devices A = O / B = I				
color of the label		A = black / B = black			
number of inscription plates	· ·				
Certificates/ approvals					
General Product Approval					
	Confirmation	Ű		EHC	
Declaration of Conformity	Test Certificates	3	other	Environment	
UK CA EG-Konf.	<u>Special Test Cer</u> <u>ate</u>	tific- <u>Type Test Certific</u> <u>ates/Test Report</u>		Environmental Con- firmations	
Further information Siemens has decided to exit the Russian market (see here). https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business					
Siemens is working on the renewal of the Please contact your local Siemens office EAC relevant market (other than the same	on the status of validity of t	he EAC certification if you in	ntend to import or offer to	supply these products to an	
Information on the packaging https://support.industry.siemens.com/cs/w	/w/en/view/109813875				
Information- and Downloadcenter (Cata https://www.siemens.com/ic10					
Industry Mall (Online ordering system) https://mall.industry.siemens.com/mall/en		3SU1802-0AC10-4HB1			
Cax online generator http://support.automation.siemens.com/W					

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3SU1802-0AC10-4HB1 Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3SU1802-0AC10-4HB1&lang=en









last modified:

1/26/2022 🖸