## **SIEMENS**

product brand name

Data sheet 3UG4621-1AA30

SIRIUS



Digital monitoring relay Current monitoring, 22.5 mm from 2-500 mA AC/DC Overshoot and undershoot Supply voltage: 24 V AC/DC 50 to 60 Hz DC and AC without galvanic isolation to measuring circuit ON delay and noise pulses delay 0.1 to 20 s Hysteresis 0.1 to 250 mA 1 change-over contact with or without fault buffer screw terminal Successor product for 3UG3521-1AC..

Production and the second seco	
product designation	Current monitoring relay with digital setting
product type designation	3UG4
General technical data	
product function	Current monitoring relay
design of the display	LCD
insulation voltage for overvoltage category III according to IEC 60664	
<ul> <li>with degree of pollution 3 rated value</li> </ul>	690 V
degree of pollution	3
surge voltage resistance rated value	4 kV
maximum permissible voltage for protective separation	
<ul> <li>between auxiliary and auxiliary circuit</li> </ul>	300 V
between control and auxiliary circuit	300 V
protection class IP	IP20
shock resistance according to IEC 60068-2-27	sinusoidal half-wave 15g / 11 ms
vibration resistance according to IEC 60068-2-6	1 6 Hz: 15 mm, 6 500 Hz: 2g
mechanical service life (operating cycles) typical	10 000 000
electrical endurance (operating cycles) at AC-15 at 230 V typical	100 000
thermal current of the switching element with contacts maximum	5 A
reference code according to IEC 81346-2	K
relative repeat accuracy	1 %
Substance Prohibitance (Date)	05/01/2012
Product Function	
product function	
<ul> <li>overcurrent detection 1 phase</li> </ul>	Yes
<ul> <li>overcurrent detection 3 phase</li> </ul>	No
<ul> <li>undercurrent detection 1 phase</li> </ul>	Yes
<ul> <li>undercurrent detection 3 phases</li> </ul>	No
<ul> <li>overcurrent detection DC</li> </ul>	Yes
<ul> <li>undercurrent detection DC</li> </ul>	Yes
<ul> <li>current window recognition DC</li> </ul>	Yes
<ul> <li>voltage window recognition 1 phase</li> </ul>	No
<ul> <li>voltage window recognition 3 phase</li> </ul>	No
<ul> <li>adjustable open/closed-circuit current principle</li> </ul>	Yes
external reset	Yes
• auto-RESET	Yes
Supply voltage	
type of voltage of the supply voltage	AC/DC

supply voltage 1 at AC	
at 50 Hz rated value	24 V
● at 50 Hz	20.4 26.4 V
at 60 Hz rated value	24 V
● at 60 Hz	20.4 26.4 V
supply voltage 1 at DC	20.4 26.4 V
supply voltage 1 at DC rated value	24 V
Measuring circuit	
type of current for monitoring	AC/DC
measurable current	0.003 0.6 A
measurable line frequency	40 500 Hz
adjustable current response value current	
• 1	0.003 0.5 A
• 2	0.003 0.5 A
adjustable response delay time	
when starting	0.1 20 s
with lower or upper limit violation	0.1 20 s
adjustable switching hysteresis for measured current value	0.1 250 mA
buffering time in the event of power failure minimum	10 ms
accuracy of digital display	+/-1 digit
relative temperature-related measurement deviation	5 %
internal resistance of the measuring circuit	500 mΩ
Precision	
relative metering precision	5 %
temperature drift per °C	0.1 %/°C
Auxiliary circuit	
number of NC contacts delayed switching	0
number of NO contacts delayed switching	0
number of CO contacts delayed switching	1
	F 000 1/b
operating frequency with 3RT2 contactor maximum	5 000 1/h
operating frequency with 3RT2 contactor maximum  Main circuit	5 000 1/11
Main circuit	1
Main circuit number of poles for main current circuit	
Main circuit  number of poles for main current circuit  operating voltage rated value	1
Main circuit number of poles for main current circuit	1
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz	1 24 24 V 3 A
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz	1 24 24 V
Main circuit  number of poles for main current circuit operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13	1 24 24 V 3 A 3 A
Main circuit  number of poles for main current circuit operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13 • at 24 V	1 24 24 V 3 A 3 A
Main circuit  number of poles for main current circuit operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13	1 24 24 V 3 A 3 A
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V	1 24 24 V 3 A 3 A 1 A 0.2 A 0.1 A
Main circuit  number of poles for main current circuit operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum	1 24 24 V 3 A 3 A 1 A 0.2 A 0.1 A 0.005 A
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V	1 24 24 V 3 A 3 A 1 A 0.2 A 0.1 A
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output	1 24 24 V 3 A 3 A 1 A 0.2 A 0.1 A 0.005 A
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay	1 24 24 V 3 A 3 A 1 A 0.2 A 0.1 A 0.005 A
Main circuit  number of poles for main current circuit operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility	1 24 24 V 3 A 3 A 1 A 0.2 A 0.1 A 0.005 A
Main circuit  number of poles for main current circuit operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference	1 24 24 V 3 A 3 A 1 A 0.2 A 0.1 A 0.005 A
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference  • due to burst according to IEC 61000-4-4  • due to conductor-earth surge according to IEC 61000-4-5  • due to conductor-conductor surge according to IEC	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference  • due to burst according to IEC 61000-4-4  • due to conductor-earth surge according to IEC 61000-4-5  • due to conductor-conductor surge according to IEC 61000-4-5	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A  2 kV 2 kV 1 kV
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference  • due to burst according to IEC 61000-4-4  • due to conductor-earth surge according to IEC 61000-4-5  • due to conductor-conductor surge according to IEC 61000-4-5  field-based interference according to IEC 61000-4-3	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A  2 kV 2 kV 1 kV
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference  • due to burst according to IEC 61000-4-4  • due to conductor-earth surge according to IEC 61000-4-5  • due to conductor-conductor surge according to IEC 61000-4-5  field-based interference according to IEC 61000-4-3  electrostatic discharge according to IEC 61000-4-2	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A  2 kV 2 kV 1 kV
Main circuit  number of poles for main current circuit operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference  • due to burst according to IEC 61000-4-4  • due to conductor-earth surge according to IEC 61000-4-5  • due to conductor-conductor surge according to IEC 61000-4-5  field-based interference according to IEC 61000-4-3	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A  2 kV 2 kV 1 kV
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference  • due to burst according to IEC 61000-4-4  • due to conductor-earth surge according to IEC 61000-4-5  • due to conductor-conductor surge according to IEC 61000-4-5  field-based interference according to IEC 61000-4-3  electrostatic discharge according to IEC 61000-4-2	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A  2 kV 2 kV 1 kV
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference  • due to burst according to IEC 61000-4-4  • due to conductor-earth surge according to IEC 61000-4-5  • due to conductor-conductor surge according to IEC 61000-4-5  field-based interference according to IEC 61000-4-3  electrostatic discharge according to IEC 61000-4-2  Galvanic isolation	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A  2 kV 2 kV 1 kV  10 V/m 6 kV contact discharge / 8 kV air discharge
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference  • due to burst according to IEC 61000-4-4  • due to conductor-earth surge according to IEC 61000-4-5  • due to conductor-conductor surge according to IEC 61000-4-5  field-based interference according to IEC 61000-4-3  electrostatic discharge according to IEC 61000-4-2  Galvanic isolation  design of the electrical isolation	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A  2 kV 2 kV 1 kV  10 V/m 6 kV contact discharge / 8 kV air discharge
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference  • due to burst according to IEC 61000-4-4  • due to conductor-earth surge according to IEC 61000-4-5  • due to conductor-conductor surge according to IEC 61000-4-5  field-based interference according to IEC 61000-4-3  electrostatic discharge according to IEC 61000-4-2  Galvanic isolation  design of the electrical isolation  galvanic isolation  • between input and output  • between the outputs	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A  2 kV 2 kV 1 kV  10 V/m 6 kV contact discharge / 8 kV air discharge
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference  • due to burst according to IEC 61000-4-4  • due to conductor-earth surge according to IEC 61000-4-5  • due to conductor-conductor surge according to IEC 61000-4-5  field-based interference according to IEC 61000-4-3  electrostatic discharge according to IEC 61000-4-2  Galvanic isolation  design of the electrical isolation  galvanic isolation  • between input and output	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A  2 kV 2 kV 1 kV 10 V/m 6 kV contact discharge / 8 kV air discharge
Main circuit  number of poles for main current circuit  operating voltage rated value  ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz  • at 400 V at 50/60 Hz  ampacity of the output relay at DC-13  • at 24 V  • at 125 V  • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference  • due to burst according to IEC 61000-4-4  • due to conductor-earth surge according to IEC 61000-4-5  • due to conductor-conductor surge according to IEC 61000-4-5  field-based interference according to IEC 61000-4-3  electrostatic discharge according to IEC 61000-4-2  Galvanic isolation  design of the electrical isolation  galvanic isolation  • between input and output  • between the outputs	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A  2 kV 2 kV 1 kV 10 V/m 6 kV contact discharge / 8 kV air discharge
Main circuit  number of poles for main current circuit operating voltage rated value ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz • at 400 V at 50/60 Hz ampacity of the output relay at DC-13  • at 24 V • at 125 V • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-earth surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC 61000-4-5  field-based interference according to IEC 61000-4-3 electrostatic discharge according to IEC 61000-4-2  Galvanic isolation  design of the electrical isolation galvanic isolation • between input and output • between the outputs • between the voltage supply and other circuits	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A  2 kV 2 kV 1 kV 10 V/m 6 kV contact discharge / 8 kV air discharge  Protective separation  Yes Yes
mumber of poles for main current circuit operating voltage rated value ampacity of the output relay at AC-15  • at 250 V at 50/60 Hz • at 400 V at 50/60 Hz ampacity of the output relay at DC-13  • at 24 V • at 125 V • at 250 V  operational current at 17 V minimum  continuous current of the DIAZED fuse link of the output relay  Electromagnetic compatibility  conducted interference • due to burst according to IEC 61000-4-4 • due to conductor-conductor surge according to IEC 61000-4-5 • due to conductor-conductor surge according to IEC 61000-4-5  field-based interference according to IEC 61000-4-3 electrostatic discharge according to IEC 61000-4-2  Galvanic isolation  design of the electrical isolation galvanic isolation • between input and output • between the outputs • between the voltage supply and other circuits  Connections/ Terminals	1 24 24 V  3 A 3 A 1 A 0.2 A 0.1 A 0.005 A 4 A  2 kV 2 kV 1 kV 10 V/m 6 kV contact discharge / 8 kV air discharge  Protective separation  Yes Yes No

ype terminals  4.0 mm²), 2x (0.5 2.5 mm²)  2.5 mm²), 2x (0.5 1.5 mm²)  14)  14)  mm²  5 mm²    mounting  m	
wpe terminals 4.0 mm²), 2x (0.5 2.5 mm²) 2.5 mm²), 2x (0.5 1.5 mm²) 14) 14) 14) 14) 14 2.5 mm² 14	
4.0 mm²), 2x (0.5 2.5 mm²) 2.5 mm²), 2x (0.5 1.5 mm²) 14) 14) mm² .5 mm²	
2.5 mm²), 2x (0.5 1.5 mm²) 14) 14) mm² .5 mm² 4 4 .2 N·m	
2.5 mm²), 2x (0.5 1.5 mm²) 14) 14) mm² .5 mm² 4 4 .2 N·m	
14) 14) mm² 5 mm²  4 4 2. N·m	
14)  mm² .5 mm²  4 4 .2 N·m	
mm² .5 mm²	
.5 mm²  L L L L L L L L L L L L L L L L L L	
.5 mm²  L L L L L L L L L L L L L L L L L L	
↓ ↓ .2 N·m n mounting	
.2 N·m  n mounting	
.2 N·m  n mounting	
.2 N·m n mounting	
n mounting	
n	
0 mm	
0 mm	
0 mm	
1	
0°C	
-40 +85 °C	
-40 +85 °C	
EMC Declaration of Conformity	

Declaration of Conformity

**Test Certificates** 

other

Marine / Shipping



Special Test Certificate

Type Test Certificates/Test Report





Confirmation

Railway

Vibration and Shock

## **Further information**

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3UG4621-1AA30

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3UG4621-1AA30

 $Service \& Support \ (Manuals, \ Certificates, \ Characteristics, \ FAQs, ...)$ 

https://support.industry.siemens.com/cs/ww/en/ps/3UG4621-1AA30

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3UG4621-1AA30&lang=en

**Characteristic: Derating** 

https://support.industry.siemens.com/cs/ww/en/ps/3UG4621-1AA30/manual

last modified:	12/21/2020