## SIEMENS

## Data sheet

## 3UG4583-1CW30



Insulation monitoring relay for ungrounded (IT) supply systems up to 400 V AC, 15-400 Hz and up to 600 V DC Measuring range 1-100 / 2-200 kohm Supply voltage 24-240 V AC/DC Width 45 mm 1 + 1 or 2 change-over contacts screw terminal

product brand name	SIRIUS
product designation	Insulation monitoring relay with analog setting
product type designation	3UG4
General technical data	
product function	Insulation monitor
type of voltage	
<ul> <li>for monitoring</li> </ul>	AC/DC
<ul> <li>of the operating voltage for actuation</li> </ul>	AC/DC
<ul> <li>of the control supply voltage</li> </ul>	AC/DC
surge voltage resistance rated value	4 000 V
protection class IP	IP20
thermal current of the switching element with contacts maximum	4 A
reference code according to IEC 81346-2	К
Substance Prohibitance (Date)	05/01/2012
Product Function	
product function	
error memory	Yes
Control circuit/ Control	
control supply voltage at AC	
<ul> <li>at 50 Hz rated value</li> </ul>	24 240 V
• at 60 Hz rated value	24 240 V
control supply voltage at DC rated value	24 240 V
operating range factor control supply voltage rated value at DC	
initial value	0.85
<ul> <li>full-scale value</li> </ul>	1.1
operating range factor control supply voltage rated value at AC at 50 Hz	
initial value	0.85
<ul> <li>full-scale value</li> </ul>	1.1
operating range factor control supply voltage rated value at AC at 60 Hz	
<ul> <li>initial value</li> </ul>	0.85
• full-scale value	1.1
Measuring circuit	
measurable line frequency	15 400 Hz
measurable voltage at AC	0 400 V
Auxiliary circuit	
number of NC contacts for auxiliary contacts	0
number of NC contacts delayed switching	0

0
0
0
2
2
15 400 Hz
Na
No
screw-type terminals
2x (0.75 2.5 mm²)
2x (0.75 2.5 mm <sup>2</sup> )
0.75 2.5 mm²
0.75 2.5 mm²
2012
18 14
0.6 0.8 N·m
any
snap-on fastening on 35 mm DIN rail
78 mm
45 mm
100 mm
0 mm
0 mm
0 mm
-25 +60 °C
EMC Declaration of Con-
formity
· · · · · · · · · · · · · · · · · · ·
RCM EG-Konf.



Special Test Certificate







Railway

Vibration and Shock

Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3UG4583-1CW30

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3UG4583-1CW30

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


https://support.industry.siemens.com/cs/ww/en/ps/3UG4583-1CW30


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)


http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3UG4583-1CW30&lang=en


Characteristic: Derating

https://support.industry.siemens.com/cs/ww/en/ps/3UG4583-1CW30/manual









11/21/2022 🖸

7/10/2023