

"'STALLATION INSTRUCTION FOR L-929 FLOATING CANOPY AND CONNECTORS

NOTE: For use with L-640 Series Track System ONLY Electrical Ratings: 120/240V. Single Phase 3-Wire with Ground Neutral, 60HZ, 20A


Locate junction box in ceiling or on wall containing two black wires (Hot +) and a white (Neutral —), MAKE SURE TO SPLICE WHITE TO WHITE, AND BLACK TO BLACK. Note: Connect the green ground wire to the green ground screw or the green wire in the junction box.



Single Phase 120V




Single Phase 120/240V 3 Wire Grounded Neutral



Wiring Diagram For L-840 Series Track

Unit consists of mounting bracket, 2 connectors, canopy cover with 2 screws, and dead-end connector.

After wires are connected, push wires into junction box and attach mounting bracket (a) to junction box.




MIGHTEN SET


SCREWS ON BOTH SIDES)

Attach dead end connector to trac and position trac on mounting bracket. Attach trac to ceiling first, then tighten set screws on either side of the trac.

Twist connector (A & (B) 90°. Make sure that the two contact fingers turn into the two slots. (Buss Bar)



TIGHTEN LOCKING SCREW



Place canopy cover © over connectors and trac and attach with two screws.

