

CERTIFICATE OF COMPLIANCE

Certificate Number 20190502-E10514
Report Reference E10514-19730711
Issue Date 2019-MAY-02

Issued to: KILLARK, DIV OF HUBBELL INC (DELAWARE)
3940 MARTIN LUTHER KING DR
ST LOUIS MO 63113

**This certificate confirms that
representative samples of**

OUTLET BOXES FOR USE IN HAZARDOUS LOCATIONS
Series GES, Cat. Nos. GES followed by CAT-4, CT-4, LAT-4, LBT-4, LT-4, NT-4, TAT-4, TT-4, AT-4, and XT-4, may be followed by M conduit boxes for use in Class I, Group D and Class II, Groups E, F and G hazardous locations.

Suffix M denotes ductile iron body and aluminum cover. If no suffix is used, both the cover and body are aluminum.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

