

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Terminal blocks for copper conductors
Name and address of the applicant	Weidmüller Interface GmbH & Co. KG Klingenbergstrae 16, 32758 Detmold Germany
Name and address of the manufacturer	Weidmüller Interface GmbH & Co. KG Klingenbergstrae 16, 32758 Detmold Germany
Name and address of the factory	<input type="checkbox"/> Additional information on page 2
Note: When more than one factory, please report on page 2	Weidmüller Interface GmbH & Co. KG Klingenbergstrae 16, 32758 Detmold Germany
Ratings and principal characteristics	500 V, 6 kV, 32 A, 4 mm <sup>2</sup>
Trademark (if any)	WEIDMÜLLER
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	WTL 4
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-7-1:2009
As shown in the Test Report Ref. No. which forms part of this Certificate	2215516.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

