



A CSW Industrials Company

metacaulk®

150+

Elastomeric



Firestop Sealant

- Penetrations & joint applications
- Flexible cure
- 3-year shelf life
- Non-sag
- Caulk grade


W-RATING

TESTED LEVEL OF PROTECTION FROM WATER INTRUSION

33 UL systems passed the water leakage test to obtain Class 1 W-rating


We draw the line at fire & smoke penetration.

For more information visit metacaulk.com/mc150

 **CLASSIFIED**
 UL
 US

FILL, VOID OR CAVITY MATERIALS FOR USE IN THROUGH-PENETRATION FIRESTOP SYSTEMS. SEE UL FIRE RESISTANCE DIRECTORY 12/3

TESTED TO ASTM E814 (UL 1479) ASTM E1966 (UL 2079) Sound Transmission Class (STC) 65 - The test was performed in accordance with ASTM E 90-09, Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions.

 **FM**
 APPROVED

SUBJECT TO THE CONDITIONS OF APPROVAL AS A WALL AND FLOOR PENETRATION FIRE STOP WHEN INSTALLED AS DESCRIBED IN THE CURRENT EDITION OF THE FM APPROVAL GUIDE.

 **FBC**
 SYSTEM COMPATIBLE

FBC™ SYSTEM COMPATIBLE INDICATES THAT THIS PRODUCT HAS BEEN TESTED, AND IS MONITORED ON AN ONGOING BASIS, TO ASSURE ITS CHEMICAL COMPATIBILITY WITH FLOWGLARD GOLD®, BLAZEMASTER® AND CORZAN® PIPE AND FITTINGS. FBC™ Flowguard Gold®, Blazemaster® and Corzan® are licensed trademarks of The Lubrizol Corporation.

 **CLEAN AIR GOLD**

CERTIFIED CLEAN AIR GOLD

RectorSeal, LLC 2601 Spenwick Drive - Houston, TX 77055 800-231-3345 metacaulk.com

A CSW Industrials Company. RectorSeal, the logos and other trademarks are property of RectorSeal, LLC, its affiliates or its licensor's and are protected by copyright, trademark and other intellectual property laws, and may not be used without permission. RectorSeal reserves the right to change specifications without prior notice. ©2019 RectorSeal. All rights reserved. R50580-1119